



Filing Receipt

Received - 2022-01-04 11:03:24 AM
Control Number - 52667
ItemNumber - 12

Heart of Texas Electric Cooperative, Inc.

Directors:

Kermit Dreyer, Gatesville
Damon Boniface, The Grove
Paul Edge, Turnersville
Dan Foster, Cameron
Kenneth Hollas, Cameron
Allen Shows, China Spring

Brandon Young
General Manager

PHONE (254) 840-2871
P.O. BOX 357
Mc GREGOR, TEXAS 76657-0357

PHONE (254) 231-0444
P.O. BOX 598
ROSEBUD, TEXAS 76570

Officers:

President
Garland Cook, McGregor

Vice President
Larry Stock, Rosebud

Secretary-Treasurer
Bobby Nawara, Bruceville

House Bill 4150

Heart of Texas Electric has completed the required assessment of lines over Belton and Waco Lakes. Heart of Texas has completed all work in the Waco Lake area. For Belton Lake areas, required upgrades have been completed with the exception of areas inside Army Corp of Engineers parks. The Army Corp of Engineers has requested all overhead lines, including ones not in question be placed underground and are currently working on design and funding. Some lines will be permanently removed as directed by the Army Corp of Engineers.

Heart of Texas and the Army Corp of Engineers have met to determine the best route for these lines. It is understood that all lines will need to be surveyed, recorded and approved through the right of way department with the Army Corp of Engineers.

Heart of Texas is working with Joshua Brown the Belton Lake Manager and his team to complete this project in a timely manner.

The following are lines that do not meet standards are:

All lines that do not meet current standards can be deenergized within 60 minutes notice from the Army Corp of Engineers in accordance with a de-energization plan they have in effect.

Winkler Park Line; Located in Bell County on Belton Lake, The Army Corp of Engineers has requested all overhead lines, be placed underground and are currently working on design. Completion date will be determined by the Army Corps of Engineers schedule.

White Flint Park; Located in Bell County on Belton Lake, The Army Corp of Engineers has requested all overhead lines, be placed underground and are currently working on design. Completion date will be determined by the Army Corps of Engineers schedule.

Cedar Ridge Park; Located in Bell County on Belton Lake, The Army Corp of Engineers has requested all overhead lines, be placed underground and are currently working on design. Completion date will be determined by the Army Corps of Engineers schedule.

Iron Bridge Park; Located in Bell County on Belton Lake, this line has been permanently removed.

Leona Park; Located in Bell County on Belton Lake, this line has been permanently removed.

Owl Creek Security light; Located in Bell County on Belton Lake, this line has been permanently removed.

Affected Entity: Heart of Texas Electric Cooperative

PROJECT NO. 52667

AFFIDAVIT

I swear or affirm that I have personal knowledge of the facts stated in this report or am relying on people with personal knowledge, that I am competent to testify to them, and that I have the authority to submit this report on behalf of the affected entity. I further swear or affirm that all statements made in this report are true, correct, and complete.

Bryan Chandler

Signature

Bryan Chandler

Printed Name


Operations Manager


Job Title

Heart of Texas Electric Cooperative

Name of Affected Entity

Sworn and subscribed before me this 4 day of January 2022



Your Touchstone Energy® Cooperative 
This institution is an equal opportunity provider and employer